

Certificate of compliance

Applicant:

ALTENERGY POWER SYSTEM INC.

No.1 Yatai Road, Jiaxing 314050 Zhejiang Province, **P.R. China**

Grid-tied Microinverter
DS3
DS3-H
DS3-L
DS3-L-SPE

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.12 Remote information exchange
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50438:2013

Requirements for micro-generating plants to be connected in parallel with public low-voltage distribution networks

DIN V VDE V 0126-1-1:2006 (4.1 Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG). Type approval for generation units to use in Type A and Type B plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:	ZEK-ESH-P21011146	Certification Program	NSOP-0032-DEU-ZE-V01	
Certificate number:	U20-0717	LIERUNGS Date of issue:	2021-08-19	
		Certification body		
		" A = / Harring (=	DAkkS	
		a difference =	Deutsche Akkreditierungsstelle D-ZE-12024-01-00	
		Thomas Lammel		

Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

tas CPS

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH

BUREAU VERITAS Consumer Products Services Germany GmbH Oehleckerring 40, 22419 Hamburg, Germany Tel: +49 40 74041-0 cps-hamburg@de.bureauveritas.com www.bureauveritas.de/cps